

Office of The Chief Medical Officer, Ghaziabad

Ref.No DSO/IDSP/2026/ 2400

Dated:- 20-05-2026

WATER TEST REPORT

ADDRESS:- CH. CHHBIL DASS PUBLIC SCHOOL, PSP-9, SEC-4, WAVE CITY, GHAZIABAD.

PREVIOUS SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
N/A	N/A	N/A	N/A	N/A

No of sample collected: - 01

SAMPLE COLLECTION DATE	SAMPLE COLLECTION AREA	SAMPLE WATER WAS BEING USED	SAMPLE ID	RESULT
18-05-2026	RO WATER	DRINKING	7290	Satisfactory

Test Result

H₂S Water test kit : Negative (-Ve) after 24-48 hrs incubation

Comments: -

H₂S water test kit report - ve reflects that water is free from Coliforms Organism.

Recommendation:

Given water safe for drinking purpose.

- This Satisfactory report/result is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.
- Validity upto one year.

Lab Technician
DPHL Lab
Ghaziabad

Microbiologist
DPHL Lab
Ghaziabad

Epidemiologist
IDSP
Ghaziabad

District Surveillance Officer/
District Public Health Expert
Ghaziabad
District Ghaziabad

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

NO. 2401

Dated:-20-05-2026

It is certified that an inspection team headed by Mr. Jitendra Kumar, Lab technician from IDSP UNIT, Ghaziabad inspected the CH. CHHBIL DASS PUBLIC SCHOOL, PSP-9, SEC-4, WAVE CITY, GHAZIABAD on 18-05-2026 and on the basis of water Test Report Bearing no. DSO/IDSP/2026/2401..dt 20-05-2026 of IDSP, Ghaziabad certified that the CH. CHHBIL DASS PUBLIC SCHOOL, PSP-9, SEC-4, WAVE CITY, GHAZIABAD has safe water facilities for the students and member of staff of the institution school also maintaining the hygienic sanitation conditions in the school building & campus as per norms prescribed by state Government. This certificate is issued with the condition that the water quality will be maintained in future otherwise, it will automatically stand cancelled on proof.

➤ **Validity upto one year.**



(Dr. R K Gupta)

District Public Health Expert

District Surveillance Officer
Ghaziabad.
District Public Health Expert
District Ghaziabad

To

CH. CHHBIL DASS PUBLIC SCHOOL,
PSP-9, SEC-4, WAVE CITY,
GHAZIABAD.